


FOR GENERAL NOTES SEE M-3C

FOR TRENCHES WHEN NATIVE SOIL AND CLASS II IS USED AS BACKFILL

A REPORT PREPARED BY A REGISTERED SOILS ENGINEER SHALL BE SUBMITTED TO THE CITY. THE SOILS ENGINEER SHALL CERTIFY THAT THE BACKFILL IS WITHIN THE OPTIMUM MOISTURE RANGE AND HAS BEEN PROPERLY COMPACTED. THE BACKFILL SHALL BE TESTED AT EACH VERTICAL FOOT, AND EACH 50 LINEAR FEET OF TRENCH WITH A MINIMUM OF 1 TEST PER TRENCH.

Revision	By	Approved	Date	CITY OF OCEANSIDE	
				TRENCH BACKFILLING & RESURFACING	
				 CITY ENGINEER      Date	
				STANDARD DRAWING NO. M-3A	